

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0078:214 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: ADEMCO, 165 Eileen Way, Syosset, NY 11791
Contact: Harry Pashkoff (516) 921-6704 Fax (516) 364-6953

DESIGN: Model 5800Wave Wireless Siren Module. Intended to be used with listee's listed control panels that support RF Transceiver Model 5883 (CSFM Listing No. 7300-0078:211) and with specific 5800 series listed wireless transmitting devices as indicated in the manufacturers installation instructions. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation and UL label.

APPROVAL: Listed as control unit accessory for use with listee's separately listed compatible transmitters and fire alarm control units.

NOTE: This model is not intended for use with décor type receptacles.

12-22-2002KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **DECEMBER 22, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**